



Government of Bermuda

Ministry of Public Works and Environment

Department of Public Lands and Buildings

Addenda

For

**The Rebuild of the "Cacti and Succulent" House at the Botanical Gardens, 169
South Road, Paget, Bermuda**

Procurement No.: **0523A-RFQ-001**

Issued: **Monday March 17, 2025**

Submission Deadline: **Tuesday April 15, 2025 03:00:00 PM Bermuda Local Time**

Addendum No: 2

This addendum provides supplemental information

March 27, 2025

This addendum supersedes information contained in the solicitation documents issued for this procurement to the extent referenced.

This addendum forms part of the solicitation documents and will be subject to all the conditions set out in the contract conditions.

Supplemental Information

1	Reference Section:	Tender Drawings B-0346-24 -copy for estimating programmes
1	Supplemental Information:	The concrete slab area is increased. Refer to sheets S002, S003, S004, S005, S007, S011 of the drawings which were issued as addendum no. 1 for the use with estimating programmes. There is no change in the amount of reinforcement required.

2	Reference Section:	Tender Drawings B-0346-24
2	Supplemental Information:	The concrete specifications are to be read as 3500 psi throughout where 3600 psi is noted.

End of Addendum No. 2