



**Department of Works and Engineering**

**BUILD, OWN AND OPERATE PLANT  
TO PRODUCE POTABLE WATER FOR ST GEORGES  
ADDENDUM NO. 2**

---

**DATE:** 14<sup>th</sup> February 2017

**METHOD OF DELIVERY:**

POSTED ON [www.opmp.gov.bm](http://www.opmp.gov.bm)

---

This Addendum forms part of the RFP documents and will be subject to all of the conditions set out in the contract conditions.

This Addendum Two contains (Two) pages.

**Item 1 – Clarification Volume 1 – Section 3.1**

The commencement of the Service Period will be coincidental with the supply of product water through the Employer's designated product meter.

**Item 2 – Clarification Volume 1 – Section 3.3**

At the time of initiating an extension under this clause the Contractor may submit details of inflationary costs that will increase the cost of renewing the service.

**Item 3 – Clarification Volume 3 Section 1.1B**

This Section refers to the need for any space required by the Contractor over and above the designated installation area.

**Item 4 – Clarification Volume 3 Section 1.1F**

In the event of a failure of the Employer's meter by mutual consent either a temporary mechanical meter will be installed or an assessment of production will be based on hours run by the plant

**Item 5 – Clarification Volume 3 Section 1.2**

There will be no requirement for unrestricted access for the Employer's staff save the Service Manager.

**Item 6 – Clarification Volume 3 Section 2.6**

The bidder must make their own assessment of needs to deal with discharges from well cleaning. The contract will require the contract to be cleaned a minimum of once every six months and the Employer will ensure there is access for the necessary access. Any increase in cleaning frequency will be at the bidders discretion.

**Item 7 – Clarification Volume 3 Section 3.6E**

The event specified will provide a specific time and date for the commencement of Service.

**Item 8 – Clarification Volume 3 Section 6.3A**

Under the terms of the abstraction license flows must be recorded. This flow measurement does not require electronic metering

**Item 9 – Clarification Volume 3 Section 8.1**

At the time of handover of the site to the contractor all equipment remaining in the designated area is to be disposed of.

Bidders are requested to acknowledge receipt of this Addendum (two) by emailing [tjchristopher@gov.bm](mailto:tjchristopher@gov.bm)

Sincerely, Project Manager

END OF ADDENDUM two