

**CERTIFICATE OF REGISTRATION OF
A PETROLEUM STORAGE TANK**

Registration No. **1230**

**Bermuda Police Service
Police Headquarters
10 Headquarters Hill
Devonshire DV 01.
Attention : Fleet Manager**



**DEPARTMENT OF ENVIRONMENT
AND NATURAL RESOURCES
P.O. Box HM 834
Hamilton HM CX
Tel: 239-2303
email: pollutioncontrol@gov.bm**

Assessment #	Map #	Grid Ref
041421914	3/15	33657466

**THIS IS TO CERTIFY that a petroleum fuel storage tank located at:
Police Headquarters, 10 Headquarters Hill, Devonshire.**

is registered in the names of :

TANK OWNER : Rubis Energy Bermuda Ltd., P.O. Box GE 2, St. George's.

TANK OPERATOR : Bermuda Police Service, 10 Headquarters Hill, Devonshire.

LAND OWNER : Bermuda Government, 30 Parliament Street, Hamilton.

Particulars of the tank:

**Serial #/ID/Name :
Date Installed: 2008
Capacity (US gallons) : 4000
Situation: Above ground
Tank Construction: Glasteel
Pump: Submersible
Pipe Construction: Steel
Corrosion Protection: Coated
Monitoring System:**

Particulars of fuel stored:

**Type: ULSD & Gasoline
For use as: Vehicle supply
Supplied by: Rubis**

THE REGISTRATION EXPIRES ON : 20 JANUARY 2021

Issue date : 8 AUGUST 2019

Department of Environment and Natural Resources



GOVERNMENT OF BERMUDA
Ministry of Home Affairs

**Department of Environment and Natural Resources
Pollution Control Section**

Autumn 2018

To: All Fuel Storage Tank Owners & Users

Your attention is drawn to the conditions on the reverse of the certificate.

Please be advised that owners and users of petroleum fuel storage tanks are required to comply with Bermuda's Risk Based Corrective Action Guidelines in the event of any leaks or spills from the fuel tanks or associated pipelines, and when fuel tanks are moved or closed. These guidelines are available online at www.gov.bm, searching "Guidelines for the Investigation and Remediation of Soil and Groundwater Contamination".

Failure to comply with these guidelines may result in prosecution under the Water Resource Act 1975.

The Department of Environment and Natural Resources will not accept a simple written notification that a fuel tank has been removed or closed in place. Evidence of there being no adverse effects on the environment from spills and leaks will be required.

Single-walled underground fuel storage tanks that are over 20 years old shall be inspected for leaks and 'leakproofness' (to the recommendations of the fuel suppliers) on an annual basis. The Department recommends that single-walled tanks greater than 30 years old be replaced with double walled tanks with interstitial leak monitors.

Fuel spills or leaks of more than 1 gallon shall be reported to the Department of Environment and Natural Resources (email pollutioncontrol@gov.bm or phone 747-2302 or 505-3286) within 24 hours.

Should you have any questions or if you would like us to meet you at the site of the tank, then please email pollutioncontrol@gov.bm.

Geoff Smith, Ph.D.
Environmental Engineer

CERTIFICATE OF REGISTRATION OF A PETROLEUM STORAGE TANK

Registration No. **782**

**Ministry of Public Works
GAB
30 Parliament Street
Hamilton HM 12.
Attention : Public Lands & Buildings**



**DEPARTMENT OF ENVIRONMENT
AND NATURAL RESOURCES
P.O. Box HM 834
Hamilton HM CX
Tel: 239-2303
pollutioncontrol@gov.bm**

Assessment #	Map #	Grid Ref
031823416	1/8	26957755

THIS IS TO CERTIFY that a petroleum fuel storage tank located at:
Westgate Correctional Facility, 6 Pender Road, Sandys.

is registered in the names of :

TANK OWNER : Ministry of Public Works, 30 Parliament Street, Hamilton.

TANK OPERATOR : Bermuda Prison Service, P.O. Box HM 264, Hamilton.

LAND OWNER : Ministry of Public Works, 30 Parliament Street, Hamilton.

Particulars of the tank:


Serial #/ID/Name :
Date Installed: **1994**
Capacity (US gallons) : **2500**
Situation:
Tank Construction:
Pump:
Pipe Construction:
Corrosion Protection:
Monitoring System:

Particulars of fuel stored:

Type: **ULS Diesel**
For use as:
Supplied by: **SHELL**

THE REGISTRATION EXPIRES ON : 7 JULY 2022

Issue date : 13 JULY 2020


Department of Environment and Natural Resources
TO

Conditions Attached to Fuel Storage Tank Registration

- 1. The useful life of fuel storage tanks is approximately 20 to 30 years. It is recommended that any tank over 30 years old is removed. Replacement tanks shall be constructed to current industry standard (e.g. double walled, interstitial monitor)**
- 2. It is recommended that:**
 - a) Underground tanks and associated pipework shall be static tested for leaks annually by the fuel supplier or a contractor recommended by the fuel supplier. Results of the testing shall be emailed to the Department of Environment and Natural Resources when completed.**
- 3. If there is a spill or leak of fuel of more than 1 US gallon, the Department of Environment and Natural Resources shall be notified within 24 hours by email or telephone.**
- 4. Owners and users of petroleum fuel storage tanks shall comply with Bermuda's Risk Based Corrective Action Guidelines in the event of any leaks or spills from the fuel tanks or associated pipework, and when fuel tanks are moved or closed. The guidelines are available online at <https://www.gov.bm/aircraft-environmental-policy-and-waste-disposal>.**
- 5. Prior to the tank being removed, a decommissioning plan shall be submitted to and approved by the Department of Environment and Natural Resources.**
- 6. Notification shall be given to the Department of Environment and Natural Resources within 30 days of any changes in ownership of the tank or property owner or tank user.**

Department of Environment and Natural Resources contact information:

Email: pollutioncontrol@gov.bm

Telephone: Dr. Geoff Smith 747-2302

Patricia Hollis 505-3286

Dr. Shaun Lavis 538-2120

CERTIFICATE OF REGISTRATION OF A PETROLEUM STORAGE TANK

Registration No. 782

**Bermuda Prison Service
P.O. Box HM 264
Hamilton HM AX.**



DEPARTMENT OF ENVIRONMENT
AND NATURAL RESOURCES
P.O. Box HM 834
Hamilton HM CX
Tel: 239-2303
email: pollutioncontrol@gov.bm

Assessment #	Map #	Grid Ref
031823416	1/8	26957755

**THIS IS TO CERTIFY that a petroleum fuel storage tank located at:
Westgate Correctional Facility, 6 Pender Road, Sandys.**

is registered in the names of :

TANK OWNER : Ministry of Public Works, 30 Parliament Street, Hamilton.

TANK OPERATOR : Bermuda Prison Service, P.O. Box HM 264, Hamilton.

LAND OWNER : Ministry of Public Works, 30 Parliament Street, Hamilton.

Particulars of the tank:

Serial #/ID/Name :
Date Installed: **1994**
Capacity (US gallons) : **2500**
Situation:
Tank Construction:
Pump:
Pipe Construction:
Corrosion Protection:
Monitoring System:

Particulars of fuel stored:

Type: **ULS Diesel**
For use as:
Supplied by: **SHELL**

THE REGISTRATION EXPIRES ON : 7 JULY 2022

Issue date : 13 JULY 2020


Department of Environment and Natural Resources

Conditions Attached to Fuel Storage Tank Registration

- 1. The useful life of fuel storage tanks is approximately 20 to 30 years. It is recommended that any tank over 30 years old is removed. Replacement tanks shall be constructed to current industry standard (e.g. double walled, interstitial monitor)**
- 2. It is recommended that:**
 - a) Underground tanks and associated pipework shall be static tested for leaks annually by the fuel supplier or a contractor recommended by the fuel supplier. Results of the testing shall be emailed to the Department of Environment and Natural Resources when completed.**
- 3. If there is a spill or leak of fuel of more than 1 US gallon, the Department of Environment and Natural Resources shall be notified within 24 hours by email or telephone.**
- 4. Owners and users of petroleum fuel storage tanks shall comply with Bermuda's Risk Based Corrective Action Guidelines in the event of any leaks or spills from the fuel tanks or associated pipework, and when fuel tanks are moved or closed. The guidelines are available online at <https://www.gov.bm/aircraft-environmental-policy-and-waste-disposal>.**
- 5. Prior to the tank being removed, a decommissioning plan shall be submitted to and approved by the Department of Environment and Natural Resources.**
- 6. Notification shall be given to the Department of Environment and Natural Resources within 30 days of any changes in ownership of the tank or property owner or tank user.**

Department of Environment and Natural Resources contact information:

Email: pollutioncontrol@gov.bm

Telephone: Dr. Geoff Smith 747-2302

Patricia Hollis 505-3286

Dr. Shaun Lavis 538-2120

CERTIFICATE OF REGISTRATION OF A PETROLEUM STORAGE TANK

Registration No. **783**

**Bermuda Prison Service
P.O. Box HM 264
Hamilton HM AX.**



DEPARTMENT OF ENVIRONMENT
AND NATURAL RESOURCES
P.O. Box HM 834
Hamilton HM CX
Tel: 239-2303
email: pollutioncontrol@gov.bm

Assessment #	Map #	Grid Ref
031823416	1/8	26957755

THIS IS TO CERTIFY that a petroleum fuel storage tank located at:
Westgate Correctional Facility, 6 Pender Road, Sandys.

is registered in the names of :

TANK OWNER : Ministry of Public Works, 30 Parliament Street, Hamilton.

TANK OPERATOR : Bermuda Prison Service, P.O. Box HM 264, Hamilton.

LAND OWNER : Ministry of Public Works, 30 Parliament Street, Hamilton.

Particulars of the tank:

Serial #/ID/Name :
Date Installed: **1994**
Capacity (US gallons) : **4500**
Situation:
Tank Construction:
Pump:
Pipe Construction:
Corrosion Protection:
Monitoring System:

Particulars of fuel stored:

Type: **ULS Diesel**
For use as:
Supplied by: **SHELL**

THE REGISTRATION EXPIRES ON : 7 JULY 2022

Issue date : 13 JULY 2020


Department of Environment and Natural Resources

Conditions Attached to Fuel Storage Tank Registration

- 1. The useful life of fuel storage tanks is approximately 20 to 30 years. It is recommended that any tank over 30 years old is removed. Replacement tanks shall be constructed to current industry standard (e.g. double walled, interstitial monitor)**
- 2. It is recommended that:**
 - a) Underground tanks and associated pipework shall be static tested for leaks annually by the fuel supplier or a contractor recommended by the fuel supplier. Results of the testing shall be emailed to the Department of Environment and Natural Resources when completed.**
- 3. If there is a spill or leak of fuel of more than 1 US gallon, the Department of Environment and Natural Resources shall be notified within 24 hours by email or telephone.**
- 4. Owners and users of petroleum fuel storage tanks shall comply with Bermuda's Risk Based Corrective Action Guidelines in the event of any leaks or spills from the fuel tanks or associated pipework, and when fuel tanks are moved or closed. The guidelines are available online at <https://www.gov.bm/aircraft-environmental-policy-and-waste-disposal>.**
- 5. Prior to the tank being removed, a decommissioning plan shall be submitted to and approved by the Department of Environment and Natural Resources.**
- 6. Notification shall be given to the Department of Environment and Natural Resources within 30 days of any changes in ownership of the tank or property owner or tank user.**

Department of Environment and Natural Resources contact information:

Email: pollutioncontrol@gov.bm

Telephone: Dr. Geoff Smith 747-2302

Patricia Hollis 505-3286

Dr. Shaun Lavis 538-2120

CERTIFICATE OF REGISTRATION OF A PETROLEUM STORAGE TANK

Registration No. 783

Ministry of Public Works
GAB
30 Parliament Street
Hamilton HM 12.
Attention : Public Lands & Buildings



DEPARTMENT OF ENVIRONMENT
AND NATURAL RESOURCES
P.O. Box HM 834
Hamilton HM CX
Tel: 239-2303
pollutioncontrol@gov.bm

Assessment #	Map #	Grid Ref
031823416	1/8	26957755

THIS IS TO CERTIFY that a petroleum fuel storage tank located at:
Westgate Correctional Facility, 6 Pender Road, Sandys.

is registered in the names of :

TANK OWNER : Ministry of Public Works, 30 Parliament Street, Hamilton.

TANK OPERATOR : Bermuda Prison Service, P.O. Box HM 264, Hamilton.

LAND OWNER : Ministry of Public Works, 30 Parliament Street, Hamilton.

Particulars of the tank:

Serial #/ID/Name :
Date Installed: 1994
Capacity (US gallons) : 4500
Situation:
Tank Construction:
Pump:
Pipe Construction:
Corrosion Protection:
Monitoring System:

Particulars of fuel stored:

Type: ULS Diesel
For use as:
Supplied by: SHELL

THE REGISTRATION EXPIRES ON : 7 JULY 2022

Issue date : 13 JULY 2020


Department of Environment and Natural Resources
TO

Conditions Attached to Fuel Storage Tank Registration

- 1. The useful life of fuel storage tanks is approximately 20 to 30 years. It is recommended that any tank over 30 years old is removed. Replacement tanks shall be constructed to current industry standard (e.g. double walled, interstitial monitor)**
- 2. It is recommended that:**
 - a) Underground tanks and associated pipework shall be static tested for leaks annually by the fuel supplier or a contractor recommended by the fuel supplier. Results of the testing shall be emailed to the Department of Environment and Natural Resources when completed.**
- 3. If there is a spill or leak of fuel of more than 1 US gallon, the Department of Environment and Natural Resources shall be notified within 24 hours by email or telephone.**
- 4. Owners and users of petroleum fuel storage tanks shall comply with Bermuda's Risk Based Corrective Action Guidelines in the event of any leaks or spills from the fuel tanks or associated pipework, and when fuel tanks are moved or closed. The guidelines are available online at <https://www.gov.bm/aircraft-environmental-policy-and-waste-disposal>.**
- 5. Prior to the tank being removed, a decommissioning plan shall be submitted to and approved by the Department of Environment and Natural Resources.**
- 6. Notification shall be given to the Department of Environment and Natural Resources within 30 days of any changes in ownership of the tank or property owner or tank user.**

Department of Environment and Natural Resources contact information:

Email: pollutioncontrol@gov.bm

Telephone: Dr. Geoff Smith 747-2302

Patricia Hollis 505-3286

Dr. Shaun Lavis 538-2120

**CERTIFICATE OF REGISTRATION OF
A PETROLEUM STORAGE TANK**

Registration No. **784**

**Ministry of Public Works
GAB
30 Parliament Street
Hamilton HM 12.
Attention : Public Lands & Buildings**



**DEPARTMENT OF ENVIRONMENT
AND NATURAL RESOURCES
P.O. Box HM 834
Hamilton HM CX
Tel: 239-2303
pollutioncontrol@gov.bm**

Assessment #	Map #	Grid Ref
031823416	1/8	26957755

**THIS IS TO CERTIFY that a petroleum fuel storage tank located at:
Westgate Correctional Facility, 6 Pender Road, Sandys.**

is registered in the names of :

TANK OWNER : Ministry of Public Works, 30 Parliament Street, Hamilton.

TANK OPERATOR : Bermuda Prison Service, 6 Pender Road, Sandys.

LAND OWNER : Ministry of Public Works, 30 Parliament Street, Hamilton.

Particulars of the tank:

**Serial #/ID/Name :
Date Installed: 1994
Capacity (US gallons) : 2500
Situation:
Tank Construction:
Pump:
Pipe Construction:
Corrosion Protection:
Monitoring System:**

Particulars of fuel stored:

**Type: Gasoline
For use as:
Supplied by: ESSO**

THE REGISTRATION EXPIRES ON : 7 JULY 2022

Issue date : 13 JULY 2020



**Department of Environment and Natural Resources
TO**

Conditions Attached to Fuel Storage Tank Registration

1. The useful life of fuel storage tanks is approximately 20 to 30 years. It is recommended that any tank over 30 years old is removed. Replacement tanks shall be constructed to current industry standard (e.g. double walled, interstitial monitor)
2. It is recommended that:
 - a) Underground tanks and associated pipework shall be static tested for leaks annually by the fuel supplier or a contractor recommended by the fuel supplier. Results of the testing shall be emailed to the Department of Environment and Natural Resources when completed.
3. If there is a spill or leak of fuel of more than 1 US gallon, the Department of Environment and Natural Resources shall be notified within 24 hours by email or telephone.
4. Owners and users of petroleum fuel storage tanks shall comply with Bermuda's Risk Based Corrective Action Guidelines in the event of any leaks or spills from the fuel tanks or associated pipework, and when fuel tanks are moved or closed. The guidelines are available online at <https://www.gov.bm/aircraft-environmental-policy-and-waste-disposal>.
5. Prior to the tank being removed, a decommissioning plan shall be submitted to and approved by the Department of Environment and Natural Resources.
6. Notification shall be given to the Department of Environment and Natural Resources within 30 days of any changes in ownership of the tank or property owner or tank user.

Department of Environment and Natural Resources contact information:

Email: pollutioncontrol@gov.bm

Telephone: Dr. Geoff Smith 747-2302

Patricia Hollis 505-3286

Dr. Shaun Lavis 538-2120

**CERTIFICATE OF REGISTRATION OF
A PETROLEUM STORAGE TANK**

Registration No. **784**

**Bermuda Prison Service
Westgate Correctional Facility
6 Pender Road
Sandys MA 01.**



**DEPARTMENT OF ENVIRONMENT
AND NATURAL RESOURCES
P.O. Box HM 834
Hamilton HM CX
Tel: 230-2303
email: pollutioncontrol@gov.bm**

Assessment #	Map #	Grid Ref
031823416	1/8	26957755

**THIS IS TO CERTIFY that a petroleum fuel storage tank located at:
Westgate Correctional Facility, 6 Pender Road, Sandys.**

is registered in the names of :

TANK OWNER : Ministry of Public Works, 30 Parliament Street, Hamilton.

TANK OPERATOR : Bermuda Prison Service, 6 Pender Road, Sandys.

LAND OWNER : Ministry of Public Works, 30 Parliament Street, Hamilton.

Particulars of the tank:

Serial #/ID/Name :
Date Installed: 1994
Capacity (US gallons) : 2500
Situation:
Tank Construction:
Pump:
Pipe Construction:
Corrosion Protection:
Monitoring System:

Particulars of fuel stored:

Type: Gasoline
For use as:
Supplied by: ESSO

THE REGISTRATION EXPIRES ON : 7 JULY 2022

Issue date : 13 JULY 2020

Department of Environment and Natural Resources

Conditions Attached to Fuel Storage Tank Registration

1. The useful life of fuel storage tanks is approximately 20 to 30 years. It is recommended that any tank over 30 years old is removed. Replacement tanks shall be constructed to current industry standard (e.g. double walled, interstitial monitor)
2. It is recommended that:
 - a) Underground tanks and associated pipework shall be static tested for leaks annually by the fuel supplier or a contractor recommended by the fuel supplier. Results of the testing shall be emailed to the Department of Environment and Natural Resources when completed.
3. If there is a spill or leak of fuel of more than 1 US gallon, the Department of Environment and Natural Resources shall be notified within 24 hours by email or telephone.
4. Owners and users of petroleum fuel storage tanks shall comply with Bermuda's Risk Based Corrective Action Guidelines in the event of any leaks or spills from the fuel tanks or associated pipework, and when fuel tanks are moved or closed. The guidelines are available online at <https://www.gov.bm/aircraft-environmental-policy-and-waste-disposal>.
5. Prior to the tank being removed, a decommissioning plan shall be submitted to and approved by the Department of Environment and Natural Resources.
6. Notification shall be given to the Department of Environment and Natural Resources within 30 days of any changes in ownership of the tank or property owner or tank user.

Department of Environment and Natural Resources contact information:

Email: pollutioncontrol@gov.bm

Telephone: Dr. Geoff Smith 747-2302

Patricia Hollis 505-3286

Dr. Shaun Lavis 538-2120

CERTIFICATE OF REGISTRATION OF A PETROLEUM STORAGE TANK

Registration No. 849

**Ministry of Public Works
GAB
30 Parliament Street
Hamilton HM 12.
Attention : Public Lands & Buildings**



DEPARTMENT OF ENVIRONMENT
AND NATURAL RESOURCES
P.O. Box HM 834
Hamilton HM CX
Tel: 239-2303
pollutioncontrol@gov.bm

Assessment #	Map #	Grid Ref
	3/11	32207503

THIS IS TO CERTIFY that a petroleum fuel storage tank located at:
Marsh Folly Depot, 4 Marsh Folly Road, Pembroke.

is registered in the names of :

TANK OWNER : Ministry of Public Works, 30 Parliament Street, Hamilton.

TANK OPERATOR : Ministry of Public Works, 4 Marsh Folly Road, Pembroke.

LAND OWNER : Ministry of Public Works, 30 Parliament Street, Hamilton.

Particulars of the tank:

Serial #/ID/Name :
Date Installed:
Capacity (US gallons) : **1500**
Situation: **Direct buried**
Tank Construction:
Pump: **Centrifugal**
Pipe Construction:
Corrosion Protection:
Monitoring System:

Particulars of fuel stored:

Type: **ULS Diesel**
For use as: **Vehicle supply**
Supplied by: **SHELL**

THE REGISTRATION EXPIRES ON : 18 NOVEMBER 2020

Issue date : 9 OCTOBER 2018



Department of Environment and Natural Resources
TO

Conditions Attached to Fuel Storage Tank Registration

1. The useful life of fuel storage tanks is approximately 20 to 30 years. It is recommended that any tank over 30 years old is removed. Replacement tanks shall be constructed to current industry standard (e.g. double walled, interstitial monitor)
2. It is recommended that:
 - a) Underground tanks and associated pipework shall be static tested for leaks annually by the fuel supplier or a contractor recommended by the fuel supplier. Results of the testing shall be emailed to the Department of Environment and Natural Resources when completed.
3. If there is a spill or leak of fuel of more than 1 US gallon, the Department of Environment and Natural Resources shall be notified within 24 hours by email or telephone.
4. Owners and users of petroleum fuel storage tanks shall comply with Bermuda's Risk Based Corrective Action Guidelines in the event of any leaks or spills from the fuel tanks or associated pipework, and when fuel tanks are moved or closed. The guidelines are available online at <https://www.gov.bm/aircraft-environmental-policy-and-waste-disposal>.
5. Prior to the tank being removed, a decommissioning plan shall be submitted to and approved by the Department of Environment and Natural Resources.
6. Notification shall be given to the Department of Environment and Natural Resources within 30 days of any changes in ownership of the tank or property owner or tank user.

Department of Environment and Natural Resources contact information:

Email: pollutioncontrol@gov.bm

Telephone: Dr. Geoff Smith 747-2302

Patricia Hollis 505-3286

Dr. Shaun Lavis 538-2120

**CERTIFICATE OF REGISTRATION OF
A PETROLEUM STORAGE TANK**

Registration No. **850**

**Ministry of Public Works
GAB
30 Parliament Street
Hamilton HM 12.
Attention : Public Lands & Buildings**



**DEPARTMENT OF ENVIRONMENT
AND NATURAL RESOURCES
P.O. Box HM 834
Hamilton HM CX
Tel: 239-2303
pollutioncontrol@gov.bm**

Assessment #	Map #	Grid Ref
	3/11	32207503

**THIS IS TO CERTIFY that a petroleum fuel storage tank located at:
Marsh Folly Depot, 4 Marsh Folly Road, Pembroke.**

is registered in the names of :

TANK OWNER : Ministry of Public Works, 30 Parliament Street, Hamilton.

TANK OPERATOR : Ministry of Public Works, 4 Marsh Folly Road, Pembroke.

LAND OWNER : Ministry of Public Works, 30 Parliament Street, Hamilton.

Particulars of the tank:

Serial #/ID/Name :
Date Installed:
Capacity (US gallons) : 1500
Situation: Direct buried
Tank Construction:
Pump: Centrifugal
Pipe Construction:
Corrosion Protection:
Monitoring System:

Particulars of fuel stored:

Type: Gasoline
For use as: Vehicle supply
Supplied by: SHELL

THE REGISTRATION EXPIRES ON : 18 NOVEMBER 2020

Issue date : 9 OCTOBER 2018



Department of Environment and Natural Resources
TO

Conditions Attached to Fuel Storage Tank Registration

1. The useful life of fuel storage tanks is approximately 20 to 30 years. It is recommended that any tank over 30 years old is removed. Replacement tanks shall be constructed to current industry standard (e.g. double walled, interstitial monitor)
2. It is recommended that:
 - a) Underground tanks and associated pipework shall be static tested for leaks annually by the fuel supplier or a contractor recommended by the fuel supplier. Results of the testing shall be emailed to the Department of Environment and Natural Resources when completed.
3. If there is a spill or leak of fuel of more than 1 US gallon, the Department of Environment and Natural Resources shall be notified within 24 hours by email or telephone.
4. Owners and users of petroleum fuel storage tanks shall comply with Bermuda's Risk Based Corrective Action Guidelines in the event of any leaks or spills from the fuel tanks or associated pipework, and when fuel tanks are moved or closed. The guidelines are available online at <https://www.gov.bm/aircraft-environmental-policy-and-waste-disposal>.
5. Prior to the tank being removed, a decommissioning plan shall be submitted to and approved by the Department of Environment and Natural Resources.
6. Notification shall be given to the Department of Environment and Natural Resources within 30 days of any changes in ownership of the tank or property owner or tank user.

Department of Environment and Natural Resources contact information:

Email: pollutioncontrol@gov.bm

Telephone: Dr. Geoff Smith 747-2302

Patricia Hollis 505-3286

Dr. Shaun Lavis 538-2120

CERTIFICATE OF REGISTRATION OF A PETROLEUM STORAGE TANK

Registration No. **848**

Ministry of Public Works
GAB
30 Parliament Street
Hamilton HM 12.
Attention : Public Lands & Buildings



DEPARTMENT OF ENVIRONMENT
AND NATURAL RESOURCES
P.O. Box HM 834
Hamilton HM CX
Tel: 239-2303
pollutioncontrol@gov.bm

Assessment #	Map #	Grid Ref
	3/11	32207503

THIS IS TO CERTIFY that a petroleum fuel storage tank located at:
Marsh Folly Depot, 4 Marsh Folly Road, Pembroke.

is registered in the names of :

TANK OWNER : **Ministry of Public Works, 30 Parliament Street, Hamilton.**

TANK OPERATOR : **Ministry of Public Works, 4 Marsh Folly Road, Pembroke.**

LAND OWNER : **Ministry of Public Works, 30 Parliament Street, Hamilton.**

Particulars of the tank:

Serial #/ID/Name :
Date Installed:
Capacity (US gallons) : **1500**
Situation: **Direct buried**
Tank Construction: **Steel, 1-wall**
Pump: **Gilbarco pump**
Pipe Construction: **Steel**
Corrosion Protection: **None**
Monitoring System: **none**

Particulars of fuel stored:

Type: **Gasoline**
For use as: **Vehicle supply**
Supplied by: **ESSO**

THE REGISTRATION EXPIRES ON : **18 NOVEMBER 2020**

Issue date : **9 OCTOBER 2018**


Department of Environment and Natural Resources
TO

Conditions Attached to Fuel Storage Tank Registration

1. The useful life of fuel storage tanks is approximately 20 to 30 years. It is recommended that any tank over 30 years old is removed. Replacement tanks shall be constructed to current industry standard (e.g. double walled, interstitial monitor)
2. It is recommended that:
 - a) Underground tanks and associated pipework shall be static tested for leaks annually by the fuel supplier or a contractor recommended by the fuel supplier. Results of the testing shall be emailed to the Department of Environment and Natural Resources when completed.
3. If there is a spill or leak of fuel of more than 1 US gallon, the Department of Environment and Natural Resources shall be notified within 24 hours by email or telephone.
4. Owners and users of petroleum fuel storage tanks shall comply with Bermuda's Risk Based Corrective Action Guidelines in the event of any leaks or spills from the fuel tanks or associated pipework, and when fuel tanks are moved or closed. The guidelines are available online at <https://www.gov.bm/aircraft-environmental-policy-and-waste-disposal>.
5. Prior to the tank being removed, a decommissioning plan shall be submitted to and approved by the Department of Environment and Natural Resources.
6. Notification shall be given to the Department of Environment and Natural Resources within 30 days of any changes in ownership of the tank or property owner or tank user.

Department of Environment and Natural Resources contact information:

Email: pollutioncontrol@gov.bm

Telephone: Dr. Geoff Smith 747-2302

Patricia Hollis 505-3286

Dr. Shaun Lavis 538-2120

CERTIFICATE OF REGISTRATION OF A PETROLEUM STORAGE TANK

Registration No. **843**

Ministry of Public Works
GAB
30 Parliament Street
Hamilton HM 12.
Attention : Public Lands & Buildings



DEPARTMENT OF ENVIRONMENT
AND NATURAL RESOURCES
P.O. Box HM 834
Hamilton HM CX
Tel: 239-2303
pollutioncontrol@gov.bm

Assessment #	Map #	Grid Ref
080094112	6/2	39407910

THIS IS TO CERTIFY that a petroleum fuel storage tank located at:
The Quarry, 18 Quarry Road, Hamilton Parish.

is registered in the names of :

TANK OWNER : Ministry of Public Works, 30 Parliament Street, Hamilton.

TANK OPERATOR : Ministry of Public Works, 18 Quarry Road, Hamilton Parish.

LAND OWNER : Ministry of Public Works, 30 Parliament Street, Hamilton.

Particulars of the tank:

Serial #/ID/Name :
Date Installed: **1966**
Capacity (US gallons) : **1500**
Situation: **Direct buried**
Tank Construction: **Steel, 1-wall**
Pump: **Gilbarro Pump**
Pipe Construction: **Steel**
Corrosion Protection: **None**
Monitoring System: **none**

Particulars of fuel stored:

Type: **Gasoline**
For use as: **supply to vehicles**
Supplied by:

THE REGISTRATION EXPIRES ON : **18 NOVEMBER 2020**

Issue date : **9 OCTOBER 2018**


Department of Environment and Natural Resources
TO

Conditions Attached to Fuel Storage Tank Registration

1. The useful life of fuel storage tanks is approximately 20 to 30 years. It is recommended that any tank over 30 years old is removed. Replacement tanks shall be constructed to current industry standard (e.g. double walled, interstitial monitor)
2. It is recommended that:
 - a) Underground tanks and associated pipework shall be static tested for leaks annually by the fuel supplier or a contractor recommended by the fuel supplier. Results of the testing shall be emailed to the Department of Environment and Natural Resources when completed.
3. If there is a spill or leak of fuel of more than 1 US gallon, the Department of Environment and Natural Resources shall be notified within 24 hours by email or telephone.
4. Owners and users of petroleum fuel storage tanks shall comply with Bermuda's Risk Based Corrective Action Guidelines in the event of any leaks or spills from the fuel tanks or associated pipework, and when fuel tanks are moved or closed. The guidelines are available online at <https://www.gov.bm/aircraft-environmental-policy-and-waste-disposal>.
5. Prior to the tank being removed, a decommissioning plan shall be submitted to and approved by the Department of Environment and Natural Resources.
6. Notification shall be given to the Department of Environment and Natural Resources within 30 days of any changes in ownership of the tank or property owner or tank user.

Department of Environment and Natural Resources contact information:

Email: pollutioncontrol@gov.bm

Telephone: Dr. Geoff Smith 747-2302

Patricia Hollis 505-3286

Dr. Shaun Lavis 538-2120

**CERTIFICATE OF REGISTRATION OF
A PETROLEUM STORAGE TANK**

Registration No. **844**

**Ministry of Public Works
GAB
30 Parliament Street
Hamilton HM 12.
Attention : Public Lands & Buildings**



**DEPARTMENT OF ENVIRONMENT
AND NATURAL RESOURCES
P.O. Box HM 834
Hamilton HM CX
Tel: 239-2303
pollutioncontrol@gov.bm**

Assessment #	Map #	Grid Ref
080094112	6/2	39407910

**THIS IS TO CERTIFY that a petroleum fuel storage tank located at:
The Quarry, 18 Quarry Road, Hamilton Parish.**

is registered in the names of :

TANK OWNER : Ministry of Public Works, 30 Parliament Street, Hamilton.

TANK OPERATOR : Ministry of Public Works, 18 Quarry Road, Hamilton Parish.

LAND OWNER : Ministry of Public Works, 30 Parliament Street, Hamilton.

Particulars of the tank:

Serial #/ID/Name :
Date Installed: 1966
Capacity (US gallons) : 1500
Situation: Direct buried
Tank Construction: Steel, 1-wall
Pump: none
Pipe Construction: Steel
Corrosion Protection: None
Monitoring System: none

Particulars of fuel stored:

Type: Gasoline
For use as: supply to vehicles
Supplied by:

THE REGISTRATION EXPIRES ON : 18 NOVEMBER 2020

Issue date : 9 OCTOBER 2018

Department of Environment and Natural Resources
TO

Conditions Attached to Fuel Storage Tank Registration

1. The useful life of fuel storage tanks is approximately 20 to 30 years. It is recommended that any tank over 30 years old is removed. Replacement tanks shall be constructed to current industry standard (e.g. double walled, Interstitial monitor)
2. It is recommended that:
 - a) Underground tanks and associated pipework shall be static tested for leaks annually by the fuel supplier or a contractor recommended by the fuel supplier. Results of the testing shall be emailed to the Department of Environment and Natural Resources when completed.
3. If there is a spill or leak of fuel of more than 1 US gallon, the Department of Environment and Natural Resources shall be notified within 24 hours by email or telephone.
4. Owners and users of petroleum fuel storage tanks shall comply with Bermuda's Risk Based Corrective Action Guidelines in the event of any leaks or spills from the fuel tanks or associated pipework, and when fuel tanks are moved or closed. The guidelines are available online at <https://www.gov.bm/aircraft-environmental-policy-and-waste-disposal>.
5. Prior to the tank being removed, a decommissioning plan shall be submitted to and approved by the Department of Environment and Natural Resources.
6. Notification shall be given to the Department of Environment and Natural Resources within 30 days of any changes in ownership of the tank or property owner or tank user.

Department of Environment and Natural Resources contact information:

Email: pollutioncontrol@gov.bm

Telephone: Dr. Geoff Smith 747-2302

Patricia Hollis 505-3286

Dr. Shaun Lavis 538-2120

CERTIFICATE OF REGISTRATION OF A PETROLEUM STORAGE TANK

Registration No. **845**

Ministry of Public Works
GAB
30 Parliament Street
Hamilton HM 12.
Attention : Public Lands & Buildings



DEPARTMENT OF ENVIRONMENT
AND NATURAL RESOURCES
P.O. Box HM 834
Hamilton HM CX
Tel: 239-2303
pollutioncontrol@gov.bm

Assessment #	Map #	Grid Ref
080094112	6/2	39407910

THIS IS TO CERTIFY that a petroleum fuel storage tank located at:
The Quarry, 18 Quarry Road, Hamilton Parish.

is registered in the names of :

TANK OWNER : Ministry of Public Works, 30 Parliament Street, Hamilton.

TANK OPERATOR : Ministry of Public Works, 18 Quarry Road, Hamilton Parish.

LAND OWNER : Ministry of Public Works, 30 Parliament Street, Hamilton.

Particulars of the tank:

Serial #/ID/Name :
Date Installed: **1966**
Capacity (US gallons) : **1500**
Situation: **Direct buried**
Tank Construction: **Steel, 1-wall**
Pump: **Gilbarco pump**
Pipe Construction: **Steel**
Corrosion Protection: **None**
Monitoring System: **none**

Particulars of fuel stored:

Type: **ULS Diesel**
For use as: **supply to vehicles**
Supplied by:

THE REGISTRATION EXPIRES ON : 18 NOVEMBER 2020

Issue date : 9 OCTOBER 2018


Department of Environment and Natural Resources
TO

Conditions Attached to Fuel Storage Tank Registration

1. The useful life of fuel storage tanks is approximately 20 to 30 years. It is recommended that any tank over 30 years old is removed. Replacement tanks shall be constructed to current industry standard (e.g. double walled, interstitial monitor)
2. It is recommended that:
 - a) Underground tanks and associated pipework shall be static tested for leaks annually by the fuel supplier or a contractor recommended by the fuel supplier. Results of the testing shall be emailed to the Department of Environment and Natural Resources when completed.
3. If there is a spill or leak of fuel of more than 1 US gallon, the Department of Environment and Natural Resources shall be notified within 24 hours by email or telephone.
4. Owners and users of petroleum fuel storage tanks shall comply with Bermuda's Risk Based Corrective Action Guidelines in the event of any leaks or spills from the fuel tanks or associated pipework, and when fuel tanks are moved or closed. The guidelines are available online at <https://www.gov.bm/aircraft-environmental-policy-and-waste-disposal>.
5. Prior to the tank being removed, a decommissioning plan shall be submitted to and approved by the Department of Environment and Natural Resources.
6. Notification shall be given to the Department of Environment and Natural Resources within 30 days of any changes in ownership of the tank or property owner or tank user.

Department of Environment and Natural Resources contact information:

Email: pollutioncontrol@gov.bm

Telephone: Dr. Geoff Smith 747-2302

Patricia Hollis 505-3286

Dr. Shaun Lavis 538-2120

**CERTIFICATE OF REGISTRATION OF
A PETROLEUM STORAGE TANK**

Registration No. **846**

**Ministry of Public Works
GAB
30 Parliament Street
Hamilton HM 12.
Attention : Public Lands & Buildings**



**DEPARTMENT OF ENVIRONMENT
AND NATURAL RESOURCES
P.O. Box HM 834
Hamilton HM CX
Tel: 239-2303
pollutioncontrol@gov.bm**

Assessment #	Map #	Grid Ref
080094112	6/2	39407910

**THIS IS TO CERTIFY that a petroleum fuel storage tank located at:
The Quarry, 18 Quarry Road, Hamilton Parish.**

is registered in the names of :

TANK OWNER : Ministry of Public Works, 30 Parliament Street, Hamilton.

TANK OPERATOR : Ministry of Public Works, 18 Quarry Road, Hamilton Parish.

LAND OWNER : Ministry of Public Works, 30 Parliament Street, Hamilton.

Particulars of the tank:

Serial #/ID/Name :
Date Installed: 1966
Capacity (US gallons) : 800
Situation: Direct buried
Tank Construction: Steel, 1-wall
Pump: none
Pipe Construction: Steel
Corrosion Protection: None
Monitoring System: none

Particulars of fuel stored:

Type: ULS Diesel
For use as: supply to vehicles
Supplied by:

THE REGISTRATION EXPIRES ON : 18 NOVEMBER 2020

Issue date : 9 OCTOBER 2018



Department of Environment and Natural Resources
TO

Conditions Attached to Fuel Storage Tank Registration

1. The useful life of fuel storage tanks is approximately 20 to 30 years. It is recommended that any tank over 30 years old is removed. Replacement tanks shall be constructed to current industry standard (e.g. double walled, interstitial monitor)
2. It is recommended that:
 - a) Underground tanks and associated pipework shall be static tested for leaks annually by the fuel supplier or a contractor recommended by the fuel supplier. Results of the testing shall be emailed to the Department of Environment and Natural Resources when completed.
3. If there is a spill or leak of fuel of more than 1 US gallon, the Department of Environment and Natural Resources shall be notified within 24 hours by email or telephone.
4. Owners and users of petroleum fuel storage tanks shall comply with Bermuda's Risk Based Corrective Action Guidelines in the event of any leaks or spills from the fuel tanks or associated pipework, and when fuel tanks are moved or closed. The guidelines are available online at <https://www.gov.bm/aircraft-environmental-policy-and-waste-disposal>.
5. Prior to the tank being removed, a decommissioning plan shall be submitted to and approved by the Department of Environment and Natural Resources.
6. Notification shall be given to the Department of Environment and Natural Resources within 30 days of any changes in ownership of the tank or property owner or tank user.

Department of Environment and Natural Resources contact information:

Email: pollutioncontrol@gov.bm

Telephone: Dr. Geoff Smith 747-2302

Patricia Hollis 505-3286

Dr. Shaun Lavis 538-2120

**CERTIFICATE OF REGISTRATION OF
A PETROLEUM STORAGE TANK**

Registration No. **847**

**Ministry of Public Works
GAB
30 Parliament Street
Hamilton HM 12.
Attention : Public Lands & Buildings**



**DEPARTMENT OF ENVIRONMENT
AND NATURAL RESOURCES
P.O. Box HM 834
Hamilton HM CX
Tel: 239-2303
pollutioncontrol@gov.bm**

Assessment #	Map #	Grid Ref
080094112	6/2	39407910

**THIS IS TO CERTIFY that a petroleum fuel storage tank located at:
The Quarry, 18 Quarry Road, Hamilton Parish.**

is registered in the names of :

TANK OWNER : Ministry of Public Works, 30 Parliament Street, Hamilton.

TANK OPERATOR : Ministry of Public Works, 18 Quarry Road, Hamilton Parish.

LAND OWNER : Ministry of Public Works, 30 Parliament Street, Hamilton.

Particulars of the tank:

Serial #/ID/Name :
Date Installed:
Capacity (US gallons) : 600
Situation: Above ground
Tank Construction: Steel, 1-wall
Pump: none
Pipe Construction: Steel
Corrosion Protection: None
Monitoring System: none

Particulars of fuel stored:

Type: ULS Diesel
For use as: asphalt production
Supplied by: ESSO

THE REGISTRATION EXPIRES ON : 18 NOVEMBER 2020

Issue date : 9 OCTOBER 2018


Department of Environment and Natural Resources
TO

Conditions Attached to Fuel Storage Tank Registration

1. The useful life of fuel storage tanks is approximately 20 to 30 years. It is recommended that any tank over 30 years old is removed. Replacement tanks shall be constructed to current industry standard (e.g. double walled, interstitial monitor)
2. It is recommended that:
 - a) Underground tanks and associated pipework shall be static tested for leaks annually by the fuel supplier or a contractor recommended by the fuel supplier. Results of the testing shall be emailed to the Department of Environment and Natural Resources when completed.
3. If there is a spill or leak of fuel of more than 1 US gallon, the Department of Environment and Natural Resources shall be notified within 24 hours by email or telephone.
4. Owners and users of petroleum fuel storage tanks shall comply with Bermuda's Risk Based Corrective Action Guidelines in the event of any leaks or spills from the fuel tanks or associated pipework, and when fuel tanks are moved or closed. The guidelines are available online at <https://www.gov.bm/aircraft-environmental-policy-and-waste-disposal>.
5. Prior to the tank being removed, a decommissioning plan shall be submitted to and approved by the Department of Environment and Natural Resources.
6. Notification shall be given to the Department of Environment and Natural Resources within 30 days of any changes in ownership of the tank or property owner or tank user.

Department of Environment and Natural Resources contact information:

Email: pollutioncontrol@gov.bm

Telephone: Dr. Geoff Smith 747-2302

Patricia Hollis 505-3286

Dr. Shaun Lavis 538-2120

**CERTIFICATE OF REGISTRATION OF
A PETROLEUM STORAGE TANK**

Registration No. **399**

**Ministry of Public Works
GAB
30 Parliament Street
Hamilton HM 12.
Attention : Public Lands & Buildings**



**DEPARTMENT OF ENVIRONMENT
AND NATURAL RESOURCES
P.O. Box HM 834
Hamilton HM CX
Tel: 239-2303
pollutioncontrol@gov.bm**

Assessment #	Map #	Grid Ref
080094112	6/2	39407910

**THIS IS TO CERTIFY that a petroleum fuel storage tank located at:
The Quarry, 18 Quarry Road, Hamilton Parish.**

is registered in the names of :

TANK OWNER : Ministry of Public Works, 30 Parliament Street, Hamilton.

TANK OPERATOR : Ministry of Public Works, P.O. Box HM 525, Hamilton.

LAND OWNER : Ministry of Public Works, 30 Parliament Street, Hamilton.

Particulars of the tank:

**Serial #/ID/Name :
Date Installed: 1996
Capacity (US gallons) : 50
Situation: Above ground
Tank Construction: Steel, 1-wall
Pump: None
Pipe Construction: Flexible, 2-wall
Corrosion Protection: None
Monitoring System:**

Particulars of fuel stored:

**Type: ULS Diesel
For use as:
Supplied by: Govt Quarry**

THE REGISTRATION EXPIRES ON : 22 NOVEMBER 2020

Issue date : 9 OCTOBER 2018

**Department of Environment and Natural Resources
TO**

Conditions Attached to Fuel Storage Tank Registration

1. The useful life of fuel storage tanks is approximately 20 to 30 years. It is recommended that any tank over 30 years old is removed. Replacement tanks shall be constructed to current industry standard (e.g. double walled, interstitial monitor)
2. It is recommended that:
 - a) Underground tanks and associated pipework shall be static tested for leaks annually by the fuel supplier or a contractor recommended by the fuel supplier. Results of the testing shall be emailed to the Department of Environment and Natural Resources when completed.
3. If there is a spill or leak of fuel of more than 1 US gallon, the Department of Environment and Natural Resources shall be notified within 24 hours by email or telephone.
4. Owners and users of petroleum fuel storage tanks shall comply with Bermuda's Risk Based Corrective Action Guidelines in the event of any leaks or spills from the fuel tanks or associated pipework, and when fuel tanks are moved or closed. The guidelines are available online at <https://www.gov.bm/aircraft-environmental-policy-and-waste-disposal>.
5. Prior to the tank being removed, a decommissioning plan shall be submitted to and approved by the Department of Environment and Natural Resources.
6. Notification shall be given to the Department of Environment and Natural Resources within 30 days of any changes in ownership of the tank or property owner or tank user.

Department of Environment and Natural Resources contact information:

Email: pollutioncontrol@gov.bm

Telephone: Dr. Geoff Smith 747-2302

Patricia Hollis 505-3286

Dr. Shaun Lavis 538-2120

CERTIFICATE OF REGISTRATION OF A PETROLEUM STORAGE TANK

Registration No. **785**

Dept. of Public Transportation
Bus Garage
26 Palmetto Road
Devonshire DV 05.



DEPARTMENT OF ENVIRONMENT
AND NATURAL RESOURCES
P.O. Box HM 834
Hamilton HM CX
Tel: 239-2303
email: pollutioncontrol@gov.bm

Assessment #	Map #	Grid Ref
041411617	3/11	33957563

THIS IS TO CERTIFY that a petroleum fuel storage tank located at:
Bus Garage, 26 Palmetto Road, Devonshire.

is registered in the names of :

TANK OWNER : Ministry of Public Works, 30 Parliament Street, Hamilton.

TANK OPERATOR : Dept. of Public Transportation, 26 Palmetto Road, Devonshire.

LAND OWNER : Ministry of Public Works, 30 Parliament Street, Hamilton.

Particulars of the tank:

Serial #/ID/Name :
Date Installed:
Capacity (US gallons) : **1500**
Situation:
Tank Construction:
Pump:
Pipe Construction:
Corrosion Protection:
Monitoring System:

Particulars of fuel stored:

Type: **Gasoline**
For use as: **supply to vehicles**
Supplied by:

THE REGISTRATION EXPIRES ON : 18 NOVEMBER 2020

Issue date : 9 OCTOBER 2018


Department of Environment and Natural Resources

Conditions Attached to Fuel Storage Tank Registration

1. The useful life of fuel storage tanks is approximately 20 to 30 years. It is recommended that any tank over 30 years old is removed. Replacement tanks shall be constructed to current industry standard (e.g. double walled, interstitial monitor)
2. It is recommended that:
 - a) Underground tanks and associated pipework shall be static tested for leaks annually by the fuel supplier or a contractor recommended by the fuel supplier. Results of the testing shall be emailed to the Department of Environment and Natural Resources when completed.
3. If there is a spill or leak of fuel of more than 1 US gallon, the Department of Environment and Natural Resources shall be notified within 24 hours by email or telephone.
4. Owners and users of petroleum fuel storage tanks shall comply with Bermuda's Risk Based Corrective Action Guidelines in the event of any leaks or spills from the fuel tanks or associated pipework, and when fuel tanks are moved or closed. The guidelines are available online at <https://www.gov.bm/aircraft-environmental-policy-and-waste-disposal>.
5. Prior to the tank being removed, a decommissioning plan shall be submitted to and approved by the Department of Environment and Natural Resources.
6. Notification shall be given to the Department of Environment and Natural Resources within 30 days of any changes in ownership of the tank or property owner or tank user.

Department of Environment and Natural Resources contact information:

Email: pollutioncontrol@gov.bm

Telephone: Dr. Geoff Smith 747-2302

Patricia Hollis 505-3286

Dr. Shaun Lavis 538-2120

CERTIFICATE OF REGISTRATION OF A PETROLEUM STORAGE TANK

Registration No. **785**

Ministry of Public Works
GAB
30 Parliament Street
Hamilton HM 12.
Attention : Public Lands & Buildings



DEPARTMENT OF ENVIRONMENT
AND NATURAL RESOURCES
P.O. Box HM 834
Hamilton HM CX
Tel: 239-2303
pollutioncontrol@gov.bm

Assessment #	Map #	Grid Ref
041411617	3/11	33957563

THIS IS TO CERTIFY that a petroleum fuel storage tank located at:
Bus Garage, 26 Palmetto Road, Devonshire.

is registered in the names of :

TANK OWNER : Ministry of Public Works, 30 Parliament Street, Hamilton.

TANK OPERATOR : Dept. of Public Transportation, 26 Palmetto Road, Devonshire.

LAND OWNER : Ministry of Public Works, 30 Parliament Street, Hamilton.

Particulars of the tank:

Serial #/ID/Name :
Date Installed:
Capacity (US gallons) : **1500**
Situation:
Tank Construction:
Pump:
Pipe Construction:
Corrosion Protection:
Monitoring System:

Particulars of fuel stored:

Type: **Gasoline**
For use as: **supply to vehicles**
Supplied by:

THE REGISTRATION EXPIRES ON : **18 NOVEMBER 2020**

Issue date : **9 OCTOBER 2018**

Department of Environment and Natural Resources
TO

Conditions Attached to Fuel Storage Tank Registration

1. The useful life of fuel storage tanks is approximately 20 to 30 years. It is recommended that any tank over 30 years old is removed. Replacement tanks shall be constructed to current industry standard (e.g. double walled, interstitial monitor)
2. It is recommended that:
 - a) Underground tanks and associated pipework shall be static tested for leaks annually by the fuel supplier or a contractor recommended by the fuel supplier. Results of the testing shall be emailed to the Department of Environment and Natural Resources when completed.
3. If there is a spill or leak of fuel of more than 1 US gallon, the Department of Environment and Natural Resources shall be notified within 24 hours by email or telephone.
4. Owners and users of petroleum fuel storage tanks shall comply with Bermuda's Risk Based Corrective Action Guidelines in the event of any leaks or spills from the fuel tanks or associated pipework, and when fuel tanks are moved or closed. The guidelines are available online at <https://www.gov.bm/aircraft-environmental-policy-and-waste-disposal>.
5. Prior to the tank being removed, a decommissioning plan shall be submitted to and approved by the Department of Environment and Natural Resources.
6. Notification shall be given to the Department of Environment and Natural Resources within 30 days of any changes in ownership of the tank or property owner or tank user.

Department of Environment and Natural Resources contact information:

Email: pollutioncontrol@gov.bm

Telephone: Dr. Geoff Smith 747-2302

Patricia Hollis 505-3286

Dr. Shaun Lavis 538-2120

CERTIFICATE OF REGISTRATION OF A PETROLEUM STORAGE TANK

Registration No. **786**

Dept. of Public Transportation
Bus Garage
26 Palmetto Road
Devonshire DV 05.



DEPARTMENT OF ENVIRONMENT
AND NATURAL RESOURCES
P.O. Box HM 834
Hamilton HM CX
Tel: 239-2303
email: pollutioncontrol@gov.bm

Assessment #	Map #	Grid Ref
041411617	3/11	33957563

THIS IS TO CERTIFY that a petroleum fuel storage tank located at:
Bus Garage, 26 Palmetto Road, Devonshire.

is registered in the names of :

TANK OWNER : Ministry of Public Works, 30 Parliament Street, Hamilton.

TANK OPERATOR : Dept. of Public Transportation, 26 Palmetto Road, Devonshire.

LAND OWNER : Ministry of Public Works, 30 Parliament Street, Hamilton.

Particulars of the tank:

Serial #/ID/Name :
Date Installed:
Capacity (US gallons): **2500**
Situation:
Tank Construction:
Pump:
Pipe Construction:
Corrosion Protection:
Monitoring System:

Particulars of fuel stored:

Type: **ULS Diesel**
For use as: **supply to vehicles**
Supplied by: **SHELL**

THE REGISTRATION EXPIRES ON : 18 NOVEMBER 2020

Issue date : 9 OCTOBER 2018


Department of Environment and Natural Resources

Conditions Attached to Fuel Storage Tank Registration

1. The useful life of fuel storage tanks is approximately 20 to 30 years. It is recommended that any tank over 30 years old is removed. Replacement tanks shall be constructed to current industry standard (e.g. double walled, interstitial monitor)
2. It is recommended that:
 - a) Underground tanks and associated pipework shall be static tested for leaks annually by the fuel supplier or a contractor recommended by the fuel supplier. Results of the testing shall be emailed to the Department of Environment and Natural Resources when completed.
3. If there is a spill or leak of fuel of more than 1 US gallon, the Department of Environment and Natural Resources shall be notified within 24 hours by email or telephone.
4. Owners and users of petroleum fuel storage tanks shall comply with Bermuda's Risk Based Corrective Action Guidelines in the event of any leaks or spills from the fuel tanks or associated pipework, and when fuel tanks are moved or closed. The guidelines are available online at <https://www.gov.bm/aircraft-environmental-policy-and-waste-disposal>.
5. Prior to the tank being removed, a decommissioning plan shall be submitted to and approved by the Department of Environment and Natural Resources.
6. Notification shall be given to the Department of Environment and Natural Resources within 30 days of any changes in ownership of the tank or property owner or tank user.

Department of Environment and Natural Resources contact information:

Email: pollutioncontrol@gov.bm

Telephone: Dr. Geoff Smith 747-2302

Patricia Hollis 505-3286

Dr. Shaun Lavis 538-2120

**CERTIFICATE OF REGISTRATION OF
A PETROLEUM STORAGE TANK**

Registration No. **786**

**Ministry of Public Works
GAB
30 Parliament Street
Hamilton HM 12.
Attention : Public Lands & Buildings**



**DEPARTMENT OF ENVIRONMENT
AND NATURAL RESOURCES
P.O. Box HM 834
Hamilton HM CX
Tel: 239-2303
pollutioncontrol@gov.bm**

Assessment #	Map #	Grid Ref
041411617	3/11	33957563

**THIS IS TO CERTIFY that a petroleum fuel storage tank located at:
Bus Garage, 26 Palmetto Road, Devonshire.**

is registered in the names of :

TANK OWNER : Ministry of Public Works, 30 Parliament Street, Hamilton.

TANK OPERATOR : Dept. of Public Transportation, 26 Palmetto Road, Devonshire.

LAND OWNER : Ministry of Public Works, 30 Parliament Street, Hamilton.

Particulars of the tank:

**Serial #/ID/Name :
Date Installed:
Capacity (US gallons) : 2500
Situation:
Tank Construction:
Pump:
Pipe Construction:
Corrosion Protection:
Monitoring System:**

Particulars of fuel stored:

**Type: ULS Diesel
For use as: supply to vehicles
Supplied by: SHELL**

THE REGISTRATION EXPIRES ON : 18 NOVEMBER 2020

Issue date : 9 OCTOBER 2018

**Department of Environment and Natural Resources
TO**

Conditions Attached to Fuel Storage Tank Registration

1. The useful life of fuel storage tanks is approximately 20 to 30 years. It is recommended that any tank over 30 years old is removed. Replacement tanks shall be constructed to current industry standard (e.g. double walled, interstitial monitor)
2. It is recommended that:
 - a) Underground tanks and associated pipework shall be static tested for leaks annually by the fuel supplier or a contractor recommended by the fuel supplier. Results of the testing shall be emailed to the Department of Environment and Natural Resources when completed.
3. If there is a spill or leak of fuel of more than 1 US gallon, the Department of Environment and Natural Resources shall be notified within 24 hours by email or telephone.
4. Owners and users of petroleum fuel storage tanks shall comply with Bermuda's Risk Based Corrective Action Guidelines in the event of any leaks or spills from the fuel tanks or associated pipework, and when fuel tanks are moved or closed. The guidelines are available online at <https://www.gov.bm/aircraft-environmental-policy-and-waste-disposal>.
5. Prior to the tank being removed, a decommissioning plan shall be submitted to and approved by the Department of Environment and Natural Resources.
6. Notification shall be given to the Department of Environment and Natural Resources within 30 days of any changes in ownership of the tank or property owner or tank user.

Department of Environment and Natural Resources contact information:

Email: pollutioncontrol@gov.bm

Telephone: Dr. Geoff Smith 747-2302

Patricia Hollis 505-3286

Dr. Shaun Lavis 538-2120

CERTIFICATE OF REGISTRATION OF A PETROLEUM STORAGE TANK

Registration No. **787**

Ministry of Public Works
GAB
30 Parliament Street
Hamilton HM 12.
Attention : Public Lands & Buildings



DEPARTMENT OF ENVIRONMENT
AND NATURAL RESOURCES
P.O. Box HM 834
Hamilton HM CX
Tel: 239-2303
pollutioncontrol@gov.bm

Assessment #	Map #	Grid Ref
041411617	3/11	33957563

THIS IS TO CERTIFY that a petroleum fuel storage tank located at:
Bus Garage, 26 Palmetto Road, Devonshire.

is registered in the names of :

TANK OWNER : Ministry of Public Works, 30 Parliament Street, Hamilton.

TANK OPERATOR : Dept. of Public Transportation, 26 Palmetto Road, Devonshire.

LAND OWNER : Ministry of Public Works, 30 Parliament Street, Hamilton.

Particulars of the tank:

Serial #/ID/Name :
Date Installed:
Capacity (US gallons) : **2500**
Situation:
Tank Construction:
Pump:
Pipe Construction:
Corrosion Protection:
Monitoring System:

Particulars of fuel stored:

Type: **ULS Diesel**
For use as: **supply to vehicles**
Supplied by: **SHELL**

THE REGISTRATION EXPIRES ON : 18 NOVEMBER 2020

Issue date : 9 OCTOBER 2018


Department of Environment and Natural Resources
TO

Conditions Attached to Fuel Storage Tank Registration

1. The useful life of fuel storage tanks is approximately 20 to 30 years. It is recommended that any tank over 30 years old is removed. Replacement tanks shall be constructed to current industry standard (e.g. double walled, interstitial monitor)
2. It is recommended that:
 - a) Underground tanks and associated pipework shall be static tested for leaks annually by the fuel supplier or a contractor recommended by the fuel supplier. Results of the testing shall be emailed to the Department of Environment and Natural Resources when completed.
3. If there is a spill or leak of fuel of more than 1 US gallon, the Department of Environment and Natural Resources shall be notified within 24 hours by email or telephone.
4. Owners and users of petroleum fuel storage tanks shall comply with Bermuda's Risk Based Corrective Action Guidelines in the event of any leaks or spills from the fuel tanks or associated pipework, and when fuel tanks are moved or closed. The guidelines are available online at <https://www.gov.bm/aircraft-environmental-policy-and-waste-disposal>.
5. Prior to the tank being removed, a decommissioning plan shall be submitted to and approved by the Department of Environment and Natural Resources.
6. Notification shall be given to the Department of Environment and Natural Resources within 30 days of any changes in ownership of the tank or property owner or tank user.

Department of Environment and Natural Resources contact information:

Email: pollutioncontrol@gov.bm

Telephone: Dr. Geoff Smith 747-2302

Patricia Hollis 505-3286

Dr. Shaun Lavis 538-2120

CERTIFICATE OF REGISTRATION OF A PETROLEUM STORAGE TANK

Registration No. 787

Dept. of Public Transportation
Bus Garage
26 Palmetto Road
Devonshire DV 05.



DEPARTMENT OF ENVIRONMENT
AND NATURAL RESOURCES
P.O. Box HM 834
Hamilton HM CX
Tel: 239-2303
email: pollutioncontrol@gov.bm

Assessment #	Map #	Grid Ref
041411617	3/11	33957563

THIS IS TO CERTIFY that a petroleum fuel storage tank located at:
Bus Garage, 26 Palmetto Road, Devonshire.

is registered in the names of :

TANK OWNER : Ministry of Public Works, 30 Parliament Street, Hamilton.

TANK OPERATOR : Dept. of Public Transportation, 26 Palmetto Road, Devonshire.

LAND OWNER : Ministry of Public Works, 30 Parliament Street, Hamilton.

Particulars of the tank:

Serial #/ID/Name :
Date Installed:
Capacity (US gallons) : **2500**
Situation:
Tank Construction:
Pump:
Pipe Construction:
Corrosion Protection:
Monitoring System:

Particulars of fuel stored:

Type: **ULS Diesel**
For use as: **supply to vehicles**
Supplied by: **SHELL**

THE REGISTRATION EXPIRES ON : 18 NOVEMBER 2020

Issue date : 9 OCTOBER 2018


Department of Environment and Natural Resources

Conditions Attached to Fuel Storage Tank Registration

1. The useful life of fuel storage tanks is approximately 20 to 30 years. It is recommended that any tank over 30 years old is removed. Replacement tanks shall be constructed to current industry standard (e.g. double walled, interstitial monitor)
2. It is recommended that:
 - a) Underground tanks and associated pipework shall be static tested for leaks annually by the fuel supplier or a contractor recommended by the fuel supplier. Results of the testing shall be emailed to the Department of Environment and Natural Resources when completed.
3. If there is a spill or leak of fuel of more than 1 US gallon, the Department of Environment and Natural Resources shall be notified within 24 hours by email or telephone.
4. Owners and users of petroleum fuel storage tanks shall comply with Bermuda's Risk Based Corrective Action Guidelines in the event of any leaks or spills from the fuel tanks or associated pipework, and when fuel tanks are moved or closed. The guidelines are available online at <https://www.gov.bm/aircraft-environmental-policy-and-waste-disposal>.
5. Prior to the tank being removed, a decommissioning plan shall be submitted to and approved by the Department of Environment and Natural Resources.
6. Notification shall be given to the Department of Environment and Natural Resources within 30 days of any changes in ownership of the tank or property owner or tank user.

Department of Environment and Natural Resources contact information:

Email: pollutioncontrol@gov.bm

Telephone: Dr. Geoff Smith 747-2302

Patricia Hollis 505-3286

Dr. Shaun Lavis 538-2120