



GOVERNMENT OF BERMUDA  
Ministry of Public Works  
Department of Works & Engineering

BEAST Septage Receiving Station  
Tynes Bay Septage Receiving Facility

**Addendum Two**

---

**DATE:** 27<sup>th</sup> January 2016

**METHOD OF DELIVERY:**

**PROJECT NAME & NO.:** 50/200

**POSTED ON** [www.opmp.gov.bm](http://www.opmp.gov.bm)

---

This Addendum forms part of the RFP documents and will be subject to all of the conditions set out in the contract conditions.

This Addendum Two contains (One) page.

**Addendum Two**

1. **Deadline for Submission of Tenders** – The deadline for the submission of tenders has been extended to 3pm on Monday 8<sup>th</sup> February 2016.
2. **Instructions to Tenderers Part 1 Sect.1.2 & Sect.1.7**– Attendance at the site visit held on 18<sup>th</sup> January 2016 is no longer a mandatory requirement for the submission of a tender. If a contractor requests to have a further site visit please make contact with;

**J Tarik Christopher Copy to: Keith Claridge**  
Email: [tjchristopher@gov.bm](mailto:tjchristopher@gov.bm) [kclaridge@gov.bm](mailto:kclaridge@gov.bm)  
or Ph: (441) 278-4219;

3. **Bidder's Questions (Q) and Government's Responses (A).**

The following are answers to queries received from bidders

**Q1. . On drawing E2 panel feeder from SS2 to Panel SS2A indicates a 1" conduit c/w 3#6 & 1#8 grd. On drawing E4 one-line it shows this feeder as 1.25" conduit c/w 3#6 & 1#6 grd  
Please clarify which feeder is correct?**

**A1. The contractor to bid on the wire and conduit size shown on drawing E4 in regards to the feeder between SS2 and Panel SS2A**

Bidders must acknowledge receipt of this Addendum (Two) by emailing  
[tjchristopher@gov.bm](mailto:tjchristopher@gov.bm) cc: [kclaridge@gov.bm](mailto:kclaridge@gov.bm)

Sincerely,

Project Manager,

END OF ADDENDUM one